



中国国家强制性产品认证证书

证书编号: 2010010307453019

委托人名称、地址

施耐德电气低压(天津)有限公司
天津经济技术开发区第七大街睦宁路66号

生产者(制造商)名称、地址

施耐德电气低压(天津)有限公司
天津经济技术开发区第七大街睦宁路66号

生产企业名称、地址

施耐德电气低压(天津)有限公司
天津经济技术开发区第七大街睦宁路66号

产品名称和系列、规格、型号

塑料外壳式断路器

iC65L;Ui:500V;Ue:AC230V(1P), AC400V(2P, 3P, 4P);
In:1A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A;过电流脱扣器类型:热磁式;
Ics=7.5kA;Icu=15kA;使用类别:A类;1P, 2P, 3P, 4P

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2013年02月25日 有效期至: 2015年12月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2010年12月30日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询




主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0670616



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2010010307453019

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Low Voltage (Tianjin) Co., Ltd.
No.66 Muning Road, 7th Avenue, TEDA, Tianjin, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Low Voltage (Tianjin) Co., Ltd.
No.66 Muning Road, 7th Avenue, TEDA, Tianjin, P.R.China

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Low Voltage (Tianjin) Co., Ltd.
No.66 Muning Road, 7th Avenue, TEDA, Tianjin, P.R.China

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

iC65L;Ui:500V;Ue:AC230V(1P), AC400V(2P, 3P, 4P);
In:1A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A; Over-current Trip Unit:Thermal-
magnetic; Ics=7.5kA;Icu=15kA;Utilization Category:A;1P, 2P, 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Feb. 25, 2013 Date of expiry: Dec. 30, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Dec. 30, 2010

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0670616



中国国家强制性产品认证证书

证书编号: 2011010307463827

委托人名称、地址

施耐德电气低压(天津)有限公司
天津经济技术开发区第七大街睦宁路66号

生产者(制造商)名称、地址

Schneider Electric Industrie S.A.S
31 rue Pierre Mendès France Eybens F-38050 Grenoble Cedex 9

生产企业名称、地址

Merlin Gerin Alès
1, rue Maurice Ravel, Zone Industrielle, de Croupillac F-30319 ALES Cédex
France

产品名称和系列、规格、型号

塑料外壳式断路器

iC65L C, iC65L D, iC60L MA iC65L C, iC65L D; Ue: AC230V(1P), AC400V
(2P, 3P, 4P); In: 32A, 40A, 50A, 63A; 过电流脱扣器类型: 热磁式; Icu=15kA,
Ics=50%Icu; 使用类别:A类; 极数:1P, 2P, 3P, 4P; iC60L MA; Ue: AC240V, AC415V;
In: 1.6A, 2.5A, 4A, 6.3A, 10A, 12.5A, 16A, 25A, 40A; 过电流脱扣器类型: 电磁式;
AC240V: Icu=30kA, Ics=50%Icu; AC415V: Icu=15kA, Ics=50%Icu; 使用类别:A类;
极数:2P, 3P

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2011年03月11日 有效期至: 2016年03月11日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0370834



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010307463827

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Low Voltage (Tianjin) Co., Ltd.
No. 66 Muning Road, 7th Avenue, TEDA, Tianjin, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industrie S.A.S
31 rue Pierre Mendès France Eybens F-38050 Grenoble Cedex 9

NAME AND ADDRESS OF THE FACTORY

Merlin Gerin Alès
1, rue Maurice Ravel, Zone Industrielle, de Croupillac F-30319 ALES Cedex
France

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-Breaker

iC65L C, iC65L D, iC60L MA iC65L C, iC65L D : Ue: AC230V (1P), AC400V
(2P, 3P, 4P); In: 32A, 40A, 50A, 63A; 过电流脱扣器类型: 热磁式; Icu=15kA,
Ics=50%Icu; 使用类别:A类; 极数:1P, 2P, 3P, 4P; iC60L MA: Ue:AC240V, AC415V;
In: 1.6A, 2.5A, 4A, 6.3A, 10A, 12.5A, 16A, 25A, 40A; 过电流脱扣器类型: 电磁式;
AC240V: Icu=30kA, Ics=50%Icu; AC415V: Icu=15kA, Ics=50%Icu; 使用类别:A类;
极数:2P, 3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Mar. 11, 2011 Date of expiry: Mar. 11, 2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0370834