

B · A · S · E · C

BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No.	(r1) :	017/004/102
Licensee:	(r4) :	PIRELLI CABLES LTD, ENERGY CABLES, PO BOX 6, LEIGH ROAD, EASTLEIGH, HANTS, SO50 9YE
Factory:	(r5) :	PIRELLI CABLES LTD, ENERGY CABLES, CHICKENHALL LANE, BISHOPSTOKE, EASTLEIGH, HAMPSHIRE, SO50 6YU
Specification	(r7) :	BS 5839-1:2002 - Fire detection and fire alarm systems for buildings - Part 1 Code of practice for system design, installation, commissioning and maintenance. Utilizing BS 7629-1:1997.
Type of Cable	(r9) :	Standard requirements of BS 5839-1:2002.
HAR Document	(r8) :	Not applicable
HAR Specification	(r10) :	Not applicable
Range of Approval	(r11) :	1.0sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. Twin and four-core inclusive. To BS EN 50200:2000 and Draft Standard BS 8434-1:2003.
Origin Thread	(r12) :	Not applicable
Origin Mark	(r13) :	PIRELLI CABLES (B) or (B) PIRELLI CABLES. (FP200 GOLD)

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to Section 4 of the BASEC Product Marking Handbook



Signed for and on behalf of the British Approvals Service for Cables

J. J. J.
Chief Executive

Date 29/07/2003 (r2)



004