

CERTIFICATE

No. 9601127 01

Product **Connecting terminal board**

*Certificate holder/
manufacturer* **WAGO Kontakttechnik GmbH
Postfach 28 80
D-32385 MINDEN
GERMANY**

Type designations **273-...**

Technical data **See enclosure 1**


*The product complies
with the standard(s)* **EN 60998-2-2:1993**

Date of expiry **31 December 2005**

Terms and additional information overleaf and in enclosure 1.

Stockholm
17 January 1996

SEMKO AB
Product Certification


Owe Richardson



SEMKO
An Inchcape
Testing Services Company

Technical Information

No. 01 Type designation: 273-...

Technical data

RATED VOLTAGE: 400 V NUMB OF TERMINALS:

MA COND AREA: 1,5 MM² KIND OF TERMINALS:

Screwless-type. 5 or 8 poles. For solid or stranded wire.

Different colours.

No. 02 Type designation: 273-...

Technical data

RATED VOLTAGE: 400 V NUMB OF TERMINALS:

MA COND AREA: 2,5 MM² KIND OF TERMINALS:

Screwless-type. 2,3,4,5, or 8 poles. For solid or stranded wire.

Different colours.

No. 03 Type designation: 273-...

Technical data

RATED VOLTAGE: 400 V NUMB OF TERMINALS:

MA COND AREA: 4 MM² KIND OF TERMINALS:

Screwless-type. 3 poles. For solid or stranded wire.

Different colours.

This certificate is based on a certificate with ref. No. 119663 BO dated 1996-01-08,
issued by DEMKO according to the Nordic Certification Service Agreement.