

Our Ref: CR/JC

10 June 2004



Henkel Loctite Adhesives
Watermead
Welwyn Garden City
Hertfordshire
AL7 1JB

Dear Sir

WATER REGULATIONS ADVISORY SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described. It has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

SEALANTS - SCREWED JOINTS - ANAEROBIC ADHESIVES

5520

Loctite 567 with activator 7649. Spray on activator then apply sealant. Cure 7 days at 7°C. White colour. For cold water and hot water use up to 85°C.

Test Report: M103258/B

0403511

HENKEL LOCTITE ADHESIVES

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, 'Materials which have passed full tests of effect on water quality'.

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory; this may be abbreviated to 'Water Regulations Advisory Scheme - Approved Product' or 'WRAS - Approved Product'. **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in March 2009.

Yours faithfully

A handwritten signature in black ink, appearing to read 'Chris Ramsey', is written over a horizontal line.

Chris Ramsey (Miss)
Materials Administrator
Water Regulations Advisory Scheme

Water Regulations Advisory Scheme
Item Group, Room 5, The Industrial Estate,
Oakridge Crescent, MK11 3SD, UK
Tel: 01495 248453 Fax: 01495 248264
E-mail: info@wrass.co.uk Website: www.wrass.co.uk

Approved by
the Drinking Water Inspectorate
under the Water Supply (Water Quality)
Regulations 1988
Approved 10/06/04