

ABB STOTZ-KONTAKT GmbH, Postfach 10 16 80, 69006 Heidelberg

ABB Limited
Tower Court
Foleshill Enterprise Park, Courtaulds Way
Coventry CV6 5NX

Person in charge	Gerhard Lauffer
Division	STO/QM
Phone	+49 6221 701 556
Fax	+49 6221 701 495
Mobile	
E-mail	Gerhard.Lauffer@de.abb.com
Our Reference	Doc. no. 2CDN070359P1002
Page	1/1
Date	Oct 31, 2014

CONFIRMATION

We hereby confirm that ABB's measuring and monitoring relay **CM-UFD.33** is type tested and complies with the relevant parts of:

Engineering Recommendation G59
G59 Issue 3 - Amendment 1 - August 2014

Engineering Recommendation G83
Issue 2 – December 2012

This confirmation is valid for the present design and for the use of the products according to the standards and as displayed in the product data sheets.

All associated confirmations / works certificates issued previously lose their validity.

With best regards,

ABB STOTZ-KONTAKT GmbH


i. V. Gerhard Lauffer
Head of Quality Management


i. A. Walter Kahl
Head of System Quality Management



ABB STOTZ-KONTAKT GmbH
Postal address:
Postfach 10 16 80
69006 Heidelberg

Visiting address:
Eppelheimer Straße 82
69123 Heidelberg
Phone +49 6221 701-0
Telefax (Purch.) +49 6221 701-693
Telefax (Sales) +49 6221 701-1377
<http://www.abb.de/stotz-kontakt>

Head Office:
Heidelberg
Registry Court:
Mannheim
Commercial Register:
HRB 336474
VAT-Id: DE811176562

Chairman of the
Supervisory Board:
Hans-Georg Krabbe
Managing Board:
Uwe Laudenklos

Bankers:
Bayerische Hypo- und
Vereinsbank AG, München
Account: 667 930 375
Sorting Code: 700 202 70
IBAN:
DE07700202700667930375
BIC: HYVEDEMMXXX